

1. WIRING INFORMATION IS SUITABLE FOR ENERVEX CASV400 THRU CASV450.

3. FOLLOW EQUIPMENT MANUFACTURER'S INSTRUCTIONS FOR PROPER INSTALLATION OF APPLIANCES.

6. ALL APPLIANCES EQUIPPED WITH A DRAFT HOOD OR BAROMETRIC DAMPER SHALL HAVE A LOCALIZED SAFETY DEVICE (THERMAL SAFETY SWITCH) TO PREVENT FLOW OF GAS TO THE MAIN BURNER IN THE EVENT OF ELECTRICAL OR MECHANICAL FAILURE OF THE DRAFT INDUCER.



INSTALLATION DETAIL FOR AN
INLINE CHIMNEY AUTOMATION
SYSTEM (CASV 400-450)
THREE PHASE 240-480V EBC-31

NOTICE: THIS DRAWING CONTAINS PROPRIETARY INFORMATION AND IT SHALL NOT BE USED, REPRODUCED OR ITS CONTENTS DISCLOSED, IN WHOLE OR IN PART, WITHOUT THE EXPRESS WRITTEN CONSENT OF ENERVEX, INCORPORATED.