



Fan		Motor	
Model	Voltage (V)	Input Voltage (V)	Current (A)
RSV 200	1x120	Max. 1x120V	1.4
RSV 250	1x120	Max. 1x120V	2.9
RSV 315	1x120	Max. 1x120V	5.8

Note:

The wire sizes shown are typical and may not apply to all jobs. This system must be installed in compliance with the NFPA 70 National Electric Code and/or any local codes.

—— Line Voltage      - - - - Low Voltage Signal

PROPRIETARY AND CONFIDENTIAL

The information contained in this drawing is the sole property of ENERVEX, Inc. Any reproduction in part or as a whole without the express written consent of ENERVEX, Inc. is prohibited.

NOT TO SCALE

**ENERVEX®**

GREEN BEFORE GREEN WAS IN

1685 Bluegrass Lakes Pkwy  
Alpharetta, GA 30004  
(770)587-3238  
Fax (770)587-4731

TITLE	CONNECTION DIAGRAM	DATE	2/2/2024
NAME	EXHAUST ONLY - EBC 24 & RSV 200-315	JOB #	Generic
DWG BY	AS	SHEET	1 OF 2
		REV	# 1